

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7300-0078:196 Page 1 of 1

**CATEGORY:** Misc. Devices/Control Unit Accessories

**LISTEE:** ADEMCO, 165 Eileen Way, Syosset, NY 11791  
Contact: Dave Kalmus (516) 921-6704

**DESIGN:** Model 472490 RF Gateway sub-assembly unit. This module is an interface between ADEMCO's Model 472462 fire alarm control unit (CSFM Listing No. 7165-0078:foc PENDING) and Model 5881 series RF receiver (CSFM Listing No. 7300-0078:162). Refer to listee's data sheet for additional detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, product designation and UL label.

**APPROVAL:** Listed as control unit accessory for use with listee's separately listed compatible fire alarm control unit as described under "Design".

11-19-99



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 8, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy  
Program Manager